

कार्यालय : मुख्य चिकित्सा अधिकारी (गाजियाबाद)

पत्रांक: /10.....

दिनांक 03/06/22.....

स्वास्थ्य एवं सफाई संबंधी अनापत्ति प्रमाण पत्र

प्रमाणित किया गया कि नवजीवन मॉडल स्कूल डी एल एफ अंकुर विहार लोनी जनपद गाजियाबाद का निरीक्षण किया गया तथा पाया गया कि स्कूल में स्वास्थ्य एवं सफाई की उचित व्यवस्था है छात्र/ छात्राओं के लिए नियमानुसार स्वास्थ्य एवं सफाई की व्यवस्थाएं संतोषजनक हैं

अतः स्कूल के पंजीकरण /नवीनीकरण हेतु स्वास्थ्य विभाग को कोई आपत्ति नहीं है।

मुख्य चिकित्सा अधिकारी

अपर मुख्य चिकित्सा अधिकारी
गाजियाबाद

Principal

NAV JEEVAN MODEL SCHOOL
(Affiliated To CBSE)
DLF, Ankur Vihar, Loni, Distt. Ghaziabad
(U.P.) Pin Code-201102

गाजियाबाद

SHRI RAM ANALYTICAL LABORATORY



Mob: 9910058519, 9910056519
 Land Line : 0120-4291739
 E-mail : shriramalab@gmail.com
 Web. : www.shriramalab.com

Test Report

Report No : SRAL/SOP/202203021056	Date : 21/03/2022
Issued To:	Your Reference : Email
Navjeevan Model School	Date of Receipt : 15/03/2022
DLF Ankur Vihar, Loni, Distt-Ghaziabad	Our Reference : Email
	Test Started on : 15/03/2022
	Test Completed on : 17/03/2022
	Page No : 1 of 1

Sample Description: One Sample Received as "Essential Analysis of Corporate Water"

"Essential Test of Corporate water"

S. No.	Parameter	Test	Essential test as per IS:10500:2012		Protocol
			Desirable Limits	Permissible Limits	
1	Colour	<5.0	5.0	15.0	IS : 3025 (pt-4)
2	Odour	Agreeable	Agreeable	Agreeable	IS : 3025 (pt-5)
3	Taste	Agreeable	Agreeable	Agreeable	IS : 3025 (pt-7)
4	Turbidity	<1.0 NTU	<1.0	5	IS : 3025 (pt-10)
5	pH Value	7.21	6.5 to 8.5	No relaxation	IS : 3025 (pt-11)
6	Total Hardness as CaCO ₃	ND	200.0	600.0	IS : 3025 (pt-21)
7	Chloride	10.9 mg/l	250.0	1000.0	IS : 3025 (pt-32)
8	Total Dissolved Solids	109 mg/l	500 mg/l	2000 mg/l	IS : 3025 (pt-16)
9	Residual Free Chlorine	ND	0.2	1	IS : 3025 (pt-26)
10	Fluoride as F	<1.0mg/l	1.0	1.5	IS : 3025 (pt-60)
11	Calcium	ND	75.0	200.0	IS : 3025 (pt-40)
12	Total Alkalinity as CaCO ₃	22 mg/l	200	600	IS : 3025 (pt-23)

"Microbiological Analysis of Corporate Water"

S. No.	Parameter	Test Result	Micro test as per IS:10500:2012		Protocol
			Desirable limit	Permissible limit	
1	Coli form	Absent	Absent/ 100ml	Absent/100ml	IS : 1622
2	E. Coli	Absent	Absent/ 100ml	Absent/100ml	IS : 1622
3	Yeast & Mould	Absent	Absent/ 100ml	Absent/ 100ml	IS : 1622
4	Total Plate Count	Absent	Absent/ 100ml	Absent/ 100ml	IS : 1622

Remark: This sample is Confirm to be IS: 10500:2012 and Suitable for Drinking Purpose.
 Note: ND= Not Detected

*** End of Report***



Terms & Conditions

- Total liability of our laboratory is limited to the Invoiced Amount. No liability will be accepted after the sample is taken back.
- The results listed refer only to the tested sample and applicable parameters. Endorsement of product is neither inferred nor implied.
- The sample description is not verified in all cases and is given "As described" by the customer. Sample not drawn by us and analysis conducted on "As Received Basis" unless specified otherwise.
- Sample description after suitable retaining period.
- All Perishable Sample such as Milk Products, Food Items etc. Immediately after reporting.
- Water Samples & Non-perishable items - after Four week of reporting (provided the party has submitted the sufficient quantity of samples)
- Any complaints about this report should be communicated in writing within 7 days of issue of this report.
- This report is not to be reproduced wholly or in parts and cannot be used as evidence in a court of law and shall not be used in advertising media without permission of CEO in writing.
- It is to be noted that utmost care is taken while preparing this report by our computer operator while feeding manually the data such as testing results, date, report number etc in the computer system. But as it is a human activity so if any clerical error/ mistakes occurs then it is just a matter of unintentional human mistake. In this case please confirm this in writing to the lab within a period of 7 days & we will rectify it within a stipulated time.
- All disputes are subject to the Ghaziabad Jurisdiction.
- We hereby declare that we are not concerned & misrepresented in any manner what it shall be to "MS. Shri Ram Institute for Industrial Research, Delhi."

Principal
 NAV JEEWAN MODEL SCHOOL
 (Affiliated To CBSE)

DLF, Ankur Vihar, 62/12, DLF Phase II, Khanna Committee Building, Ram Nagar, Kirana Mandi, Ghaziabad - 201001 (U.P.)
 (U.P.) Pin Code-201102